

REPORT- SS-A System Loads Summary for S1 Sys (PVVT)

WEATHER FILE- CZ15RV2 WYEC2

- - - - - C O O L I N G - - - - -							- - - - - H E A T I N G - - - - -						- - - E L E C - - -	
MONTH	COOLING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM COOLING LOAD (KBTU/HR)	HEATING ENERGY (MBTU)	TIME OF MAX DY HR	DRY- BULB TEMP	WET- BULB TEMP	MAXIMUM HEATING LOAD (KBTU/HR)	ELEC- TRICAL ENERGY (KWH)	MAXIMUM ELEC LOAD (KW)		
JAN	0.06924	31 16	77.F	53.F	10.527	-1.823	1 8	38.F	29.F	-19.609	649.	1.685		
FEB	0.24151	9 16	84.F	58.F	17.950	-0.727	4 8	43.F	38.F	-21.264	594.	2.379		
MAR	1.32007	16 16	87.F	55.F	27.129	-0.374	1 8	50.F	43.F	-17.260	701.	3.356		
APR	3.78476	5 16	95.F	60.F	35.256	0.000	30 1	56.F	45.F	0.000	880.	4.195		
MAY	6.73928	26 18	103.F	63.F	47.683	0.000	31 1	82.F	57.F	0.000	1208.	6.147		
JUN	12.85891	29 18	111.F	66.F	56.522	0.000	30 1	82.F	55.F	0.000	1843.	7.824		
JUL	16.83741	6 18	112.F	72.F	59.271	0.000	31 1	85.F	63.F	0.000	2206.	7.952		
AUG	17.04037	18 18	112.F	70.F	58.255	0.000	31 1	76.F	57.F	0.000	2195.	7.821		
SEP	11.60140	11 17	110.F	66.F	55.268	0.000	30 1	72.F	54.F	0.000	1691.	7.367		
OCT	6.31313	5 17	99.F	65.F	41.582	0.000	31 24	60.F	46.F	0.000	1160.	5.266		
NOV	0.69708	1 15	84.F	67.F	19.862	-0.129	30 8	48.F	44.F	-10.804	629.	2.329		
DEC	0.06980	19 15	81.F	54.F	5.859	-1.915	29 8	38.F	29.F	-20.274	649.	1.494		
TOTAL	77.573					-4.968					14404.			
MAX					59.271					-21.264		7.952		